

# TRAK-PRO GNH NAILER PINS

**FOR CONCRETE & STEEL** 

**CERTIFICATION** 

**TECHNICAL DATA** 





FOR INSTALL SUPPORT sales@allfasteners.com



FOR SPECIFICATION SUPPORT

certs@allfasteners.com



**FOR CUSTOMER SUPPORT** 888.859.6060

**Trak-Pro GNH Nailer Pins** are made out of high carbon steel ensuring strength and hardness, for use in concrete and light-gauge steel. Use with Trak-Pro Battery Nailer to fix steel plate to steel plate or to concrete.



# **KEY BENEFITS**

- Made of High Carbon Steel
- For Use in Concrete & Light-Gauge Steel

High Strength & Hardness

# **TECHNICAL SPECIFICATIONS**

## TABLE 1: ALLOWABLE TENSION LOADS IN NORMAL WEIGHT CONCRETE

	SHANK	MIN.	MIN. EDGE	IIN. EDGE MIN.		ALLOWABLE TENSION LOAD - lbs. (kn)			
PART #	DIAMETER in. (mm)	PENETRATION in. (mm)	DISTANCE in. (mm)	SPACING in. (mm)	f' <sub>c</sub> =2,500 psi (17.2 MPa)	f' <sub>c</sub> =3,000 psi (20.7 MPa)	f' <sub>c</sub> =4,000 psi (27.6 MPa)	f' <sub>c</sub> =5,000 psi (34.5 MPa)	
1 CNI	0.106 (0.7)	5/8 (16)	3 (76)	4 (102)	25 (0.11)	30 (0.13)	45 (0.20)	45 (0.20)	
1GNH 0.106 (2.7)	3/4 (19)	3 (76)	4 (102)	30 (0.13)	30 (0.13)	30 (0.13)	30 (0.13)		

- 1. The fasteners must not be driven until the concrete has reached the designated minimum compressive strength.
- 2. Minimum concrete thickness must be three times the fastener embedment into the concrete.
- 3. The allowable tension values are only for the fastener in the concrete. Members connected to the concrete must be investigated in accordance with accepted design criteria.

## TABLE 2: ALLOWABLE SHEAR LOADS IN NORMAL WEIGHT CONCRETE

	SHANK	MIN.	MIN. EDGE	MIN.	ALLOWABLE SHEAR LOAD - Ibs. (kn)			
PART #	DIAMETER in. (mm)	PENETRATION in. (mm)	DISTANCE in. (mm)	SPACING in. (mm)	f' <sub>c</sub> =2,500 psi (17.2 MPa)	f' <sub>c</sub> =3,000 psi (20.7 MPa)	f' =4,000 psi (27.6 MPa)	f' <sub>c</sub> =5,000 psi (34.5 MPa)
1 CNI.I	1GNH 0.106 (2.7)	5/8 (16)	3 (76)	4 (102)	25 (0.11)	25 (0.11)	25 (0.11)	25 (0.11)
IGNH		3/4 (19)	3 (76)	4 (102)	50 (0.22)	55 (0.24)	75 (0.33)	75 (0.33)

- 1. The fasteners must not be driven until the concrete has reached the designated minimum compressive strength.
- 2. Minimum concrete thickness must be three times the fastener embedment into the concrete.
- 3. The allowable tension values are only for the fastener in the concrete. Members connected to the concrete must be investigated in accordance with accepted design criteria.

#### TABLE 3: ALLOWABLE TENSION LOADS IN SAND-LIGHTWEIGHT CONCRETE OVER STEEL DECK

				ALLOWABLE TENSION LOAD - Ibs. (kn)			
PART #		SHANK Diameter in. (mm)	MIN. PENETRATION in. (mm)	INSTALLED IN CONCRETE <sup>4</sup>	INSTALLED THRU. 3" "W" DECK WITH 2-1/4" CONCRETE FILL <sup>6</sup>	INSTALLED THRU. 1.5" "B" DECK WITH 2-1/4" CONCRETE FILL <sup>7</sup>	
				f' <sub>c</sub> =3,000 psi (20.7 MPa) CONCRETE			
	1000	0.106 (2.7)	5/8 (16)	75 (0.33)	60 (0.27)	65 (0.29)	
	1GNH		3/4 (19)	105 (0.47)	60 (0.27)	130 (0.58)	

- 1. The fastener shall not be driven until the concrete has reached the designated compressive strength.
- 2. The allowable tension values are for the fastener only. Members connected to the concrete must be investigated separately in accordance with accepted design criteria.
- 3. Steel deck must be minimum 20 gauge and have a minimum yield strength of 38,000 psi.
- 4. The minimum fastener spacing is 4". The minimum edge distances are 3 1/2" and 3" for powder-actuated fasteners and gas-actuated fasteners, respectively.
- 5. The fastener shall be installed minimum 1 1/2" from the edge of flute and 4" from the end of the deck. The minimum fastener spacing is 4".
- 6. The fastener shall be installed minimum 1" from the edge of flute and 3" from the end of the deck. The minimum fastener spacing is 4".
- 7. The fastener shall be installed minimum 7/8" from the edge of flute. For inverted 1.5" "B" deck configuration, the fastener must be a minimum of 1" from the edge of flute. Fastener must be installed minimim 3" from the end of the deck. The minimum fastener spacing is 4".
- 8. The fastener shall be installed minimum 7/8" from the edge of flute and 4" from the end of the deck. The minimum fastener spacing is 4".

www.allfasteners.com | Customer Service 888.859.6060

# INSTALLATION SPECIFICATIONS

#### TABLE 4: ALLOWABLE SHEAR LOADS IN SAND-LIGHTWEIGHT CONCRETE OVER STEEL DECK

		MIN. PENETRATION in. (mm)	ALLOWABLE SHEAR LOAD - Ibs. (kN)			
PART #	SHANK Diameter in. (mm)		INSTALLED IN CONCRETE⁴	INSTALLED THRU. 3" "W" DECK WITH 2-1/4" CONCRETE FILL <sup>6</sup>	INSTALLED THRU. 1.5" "B" DECK WITH 2-1/4" CONCRETE FILL <sup>7</sup>	
			f' <sub>c</sub> =3,000 psi (20.7 MPa) CONCRETE			
10111	0.106 (0.7)	5/8 (16)	35 (0.16)	180 (0.60)	195 (0.87)	
1GNH	0.106 (2.7)	3/4 (19)	140 (0.62)	180 (0.60)	270 (1.20)	

- 1. The fastener shall not be driven until the concrete has reached the designated compressive strength.
- 2. The allowable tension values are for the fastener only. Members connected to the concrete must be investigated separately in accordance with accepted design criteria.
- 3. Steel deck must be minimum 20 gauge and have a minimum yield strength of 38,000 psi.
- 4. The minimum fastener spacing is 4". The minimum edge distances are 3 1/2" and 3" for powder-actuated fasteners and gas-actuated fasteners, respectively.
- 5. The fastener shall be installed minimum 1 1/2" from the edge of flute and 4" from the end of the deck. The minimum fastener spacing is 4".
- 6. The fastener shall be installed minimum 1" from the edge of flute and 3" from the end of the deck. The minimum fastener spacing is 4".
- 7. The fastener shall be installed minimum 7/8" from the edge of flute. For inverted 1.5" "B" deck configuration, the fastener must be a minimum of 1" from the edge of flute. Fastener must be installed minimim 3" from the end of the deck. The minimum fastener spacing is 4".
- 8. The fastener shall be installed minimum 7/8" from the edge of flute and 4" from the end of the deck. The minimum fastener spacing is 4".

#### TABLE 5: ALLOWABLE TENSION & SHEAR LOADS IN HOLLOW & GROUT FILLED CMU<sup>4,5</sup>

		SHANK	MIN.	MIN.	8" HOLLOW CMU		
	PART #	DIAMETER in. (mm)	PENETRATION	EDGE DISTANCE	TENSION LOAD	SHEAR LOAD	
			in. (mm)	in. (mm)	ALLOWABLE lbs. (kn)	ALLOWABLE Ibs. (kN)	
	1GNH	0.106 (2.7)	5/8 (16)	3 (76)	35¹ (0.16)	60¹ (0.27)	

- 1. Allowable values for fasteners in hollow lightweight concrete masonry units conforming to ASTM C90.
- 2. Allowable values for fasteners in hollow medium-weight concrete masonry units conforming to ASTM C90.
- 3. Allowable values for fasteners in grout-filled lightweight concrete masonry units conforming to ASTM C90 with coarse grout confroming to ASTM C746.
- 4. The minimum allowable nominal size of the CMU must be 8" high by 8" wider by 16" long, with a minimum 1 1/4"-thick face shell thickness.
- 5. Allowable values are for fasteners installed in the center of a CMU face shell. See Figure 1 for the applicable placement zone. Only one fastener may be installed at each cell.
- 6. Minimum penetration is measured from the outside face of the CMU.
- 7. Allowable values are for the fastener only. Members connected to the CMU must be investigated separately in accordance with accepted design criteria.

## TABLE 6: ALLOWABLE TENSION LOADS IN STEEL<sup>1</sup>

	SHANK	MIN.	MIN.	MIN. STEEL	ALLOWABLE TENSION LOAD - lbs. (kn)		
PART #	DIAMETER in. (mm)	EDGE DISTANCE in. (mm)	SPACING in. (mm)	STRENGTH ASTM	1/8" THICK STEEL	3/16" THICK STEEL	1/4" THICK STEEL
1 CNI.I	0.106 (0.7)	0.5 (13)	1 (25)	A36	125 (0.56)	210 (0.93)	220 (0.98)
1GNH	0.106 (2.7)	0.5 (13)	1 (25)	A572 Gr. 50 or A992	_	225 (1.00)	185 (0.82)

- 1. The entire pointed portion of the fastener must penetrate through the steel to obtain the tabulated values, unless otherwise indicated.
- 2. The allowable tension values are for the fastener only. Members connected to the steel must be investigated separately in accordance with accepted design criteria.
- 3. Steel strength must comply with the minimum requirements of ASTM A 36 (Fy = 36 ksi, Fu = 58 ksi), ASTM A 572, Grade 50 (Fy = 50 ksi, Fu = 65 ksi), or ASTM A992 (Fy = 50 ksi, Fu = 65 ksi).
- 4. Based upon minimum penetration depth of 0.46" (11.7 mm).
- 5. Based upon minimum penetration depth of 0.58" (14.7 mm).
- 6. Based upon minimum penetration depth of 0.36" (9.1 mm).
- 7. The fastener must be driven to where the point of the fastener penetrates through the steel.
- 8. Based upon minimum penetration depth of 0.35" (8.9 mm).
- 9. Based upon minimum penetration depth of 0.25" (6.4 mm).
- 10. For stepped shank fasteners: (Diameter of shank above the step.)/(Diameter of shank below the step.)

www.allfasteners.com | Customer Service 888.859.6060

# **TECHNICAL SPECIFICATIONS**

#### TABLE 7: ALLOWABLE SHEAR LOADS IN STEEL<sup>1</sup>

	SHANK	MIN.	MIN.	MIN. STEEL	ALLOWABLE SHEAR LOAD - Ibs. (kn)		
PART #	DIAMETER in. (mm)	EDGE DISTANCE in. (mm)	SPACING in. (mm)	STRENGTH ASTM	1/8" THICK STEEL	3/16" THICK STEEL	1/4" THICK STEEL
1GNH	0.106 (2.7)	0.5 (13)	1 (25)	A36	285 (1.27)	225 (1.00)	205 (0.91)
IGNI	0.106 (2.7)	0.5 (13)	1 (25)	A572 Gr. 50 or A992	_	250 (1.11)	145 (0.64)

- 1. The entire pointed portion of the fastener must penetrate through the steel to obtain the tabulated values, unless otherwise indicated.
- 2. The allowable tension values are for the fastener only. Members connected to the steel must be investigated separately in accordance with accepted design criteria.
- 3. Steel strength must comply with the minimum requirements of ASTM A 36 (Fy = 36 ksi, Fu = 58 ksi), ASTM A 572, Grade 50 (Fy = 50 ksi, Fu = 65 ksi), or ASTM A992 (Fy = 50 ksi, Fu = 65 ksi).
- 4. Based upon minimum penetration depth of 0.46" (11.7 mm).
- 5. Based upon minimum penetration depth of 0.58" (14.7 mm).
- 6. Based upon minimum penetration depth of 0.36" (9.1 mm).
- 7. The fastener must be driven to where the point of the fastener penetrates through the steel.
- 8. Based upon minimum penetration depth of 0.35" (8.9 mm).
- 9. Based upon minimum penetration depth of 0.25" (6.4 mm).
- 10. For stepped shank fasteners: (Diameter of shank above the step.)/(Diameter of shank below the step.)

# ORDERING INFORMATION

### TABLE 8: ORDERING INFORMATION 1GNH SPIRAL SHANK HARDENED PINS FOR CONCRETE & STEEL

PART NUMBER	SIZE	FINISH	QTY/B0X
1GNH034	3/4 x .109 Spiral Shank Ballistic Point Hardened Pins	Mechanical Galvanized	1000
1GNH100	1 x .109 Spiral Shank Ballistic Point Hardened Pins	Mechanical Galvanized	1000
1GNH114	1-1/4 x .109 Spiral Shank Ballistic Point Hardened Pins	Mechanical Galvanized	1000

## TABLE 9: ORDERING INFORMATION 1GNS STEP SHANK HARDENED PINS FOR STEEL

PART NUMBER	SIZE	FINISH	QTY/B0X
1GNS012	1/2 x .120 Step Shank Ballistic Point Hardened Pins Mechanical Galvanized	Mechanical Galvanized	1000

# **TOOL INFORMATION**



# TABLE 10: ORDERING INFORMATION 9BE40 TRAK-PRO CONCRETE BATTERY NAILER

PART NUMBER	T00L	KIT INCLUDES	QTY/B0X
9BE40	Cordless 18V Battery Concrete Nailer Kit	30-Pin Track, 2 Batteries & Charger	1000